

RETURN of NOTICES given to REPAIR BOILERS during the Financial Year ended the 31st March, 1890.

District, and Date of Notice.	Description of Boiler.	Nature of Repairs ordered.
WELLINGTON. 1889.		
April 1 ...	Cornish...	New gauge-mountings.
April 5 ...	Cornish...	New fusible plugs.
April 6 ...	Semi-tubular ...	New compensating-ring round man-hole.
April 6 ...	Portable ...	New crown in fire-box.
April 24 ...	Multi-tubular ...	Extra stays (longitudinal).
May 14 ...	Portable ...	Doubling piece under the cylinders, and repairs to mud doors.
July 19 ...	Portable ...	Repairs to fire-box of locomotive.
July 23 ...	Multi-tubular ...	Retubed.
July 25 ...	Vertical tubular ...	New safety-valve fitted, and man-hole cut for examination.
July 27 ...	Portable ...	Repairs to fire-box of locomotive.
Aug. 14 ...	Cornish...	Repairs to shell near feed-valve chest.
Aug. 17 ...	Semi-tubular ...	Compensating-ring round man-hole, and additional stays.
Aug. 17 ...	Cornish...	New angle-iron fitted in back end, and lower part of front plate renewed.
NELSON SOUTH.		
Aug. 19 ...	Portable ...	Repairs to mud-hole doors.
Sept. 9 ...	Multi-tubular ...	Extra stays in steam- and water-space.
Oct. 11 ...	Cornish...	Repairs to longitudinal seams.
Oct. 12 ...	Multi-tubular ...	Repairs to mud-hole doors.
Nov. 7 ...	Portable ...	New crown in fire-box, repairs to skirt, new stays in steam-space, and all new stays in fire-box.
Nov. 8 ...	Portable ...	New stays in fire-box, and repairs to skirt.
Nov. 14 ...	Portable ...	Repairs to fire-box, and patch on shell.
Nov. 21 ...	Portable ...	New stays in fire-box, and skirt repaired.
Nov. 21 ...	Semi-tubular ...	Repairs to bottom of shell, and new blow-off cock fitted.
Nov. 30 ...	Vertical ...	New lum-leg fitted.
Nov. 30 ...	Cornish...	Repairs to front plate and mud door.
Dec. 5 ...	Multi-tubular ...	Retubed.
1890.		
Jan. 8 ...	Cornish...	Strengthening-rings round partially-collapsed furnace.
TARANAKI.		
Jan. 25 ...	Portable ...	New stays on crown of fire-box.
Jan. 25 ...	Portable ...	Extra cross-stays on crown of fire-box.
Jan. 31 ...	Portable ...	Repairs to mud-hole doors, and new steam-gauge.
Feb. 2 ...	Semi-tubular ...	Compensating-ring on man-hole, and new feed-check valve.
Feb. 12 ...	Portable ...	New longitudinal stay in steam-space.
WELLINGTON.		
Feb. 24 ...	Multi-tubular ...	New plate bottom of boiler, back ring of plate.
Feb. 26 ...	Cornish...	Patch on bottom, and blow-off cock refitted.
Feb. 26 ...	Portable ...	The skirt of fire-box chipped and caulked.
Feb. 26 ...	Lancashire ...	Strengthening-rings fitted on partially-collapsed furnace-tubes.
March 27 ...	Portable ...	Patch on side of fire-box.

RETURN of Boilers in the WELLINGTON DISTRICT inspected during the Financial Year ended the 31st March, 1890, the Certificates for which have been issued Free.

	Date.	Fees.
	1889.	£ s. d.
Telegraph Department: One boiler over 10 h.p. ...	June 1 ...	3 0 0
Prisons Department: One boiler over 10 h.p. and one over 5 h.p. ...	Nov. 4 ...	5 0 0
Lunatic Asylum: Two boilers over 5 h.p. ...	Nov. 12 ...	4 0 0
Defence Department: One boiler over 10 h.p. and one over 5 h.p. ...	June 19 ...	5 0 0
Government Printer: Two boilers over 10 h.p. ...	April 18 ...	5 0 0
		£22 0 0