Return showing the Number of Land Boilers inspected in the Otago District during the Financial Year ended 31st March, 1890.

		Number	of Portable	Boilers.	Number o				
	Name of District.	5 h.p. and under.	5 to 10 h.p.	Over 10 h.p.	5 h.p. and under.	5 to 10 h.p.	Over 10 h.p.	Total.	
Otago		50	187	11	161	49	151	609	

RETURN of FEES payable for the Inspection of Boilers and Machinery in the Otago District during the Financial Year ended the 31st March, 1890.

Name of District, &c.			Fe	es payable of Boiler	-	Fccs payable in respect of Machinery.		Total.		
	Отада).		£ s	. d.	£	s. d.	£	s.	d.
Portable		•••		383 (0 (1			
Stationary				545 10	0 (930	10	0
Machinery			*** :		i	2	0 0			

RETURN of DEFECTS found on the Inspection of Boilers and Fittings in the Otago District during the Financial Year ended the 31st March, 1890.

1	n.			Dangerous.	Ordinary.	Total.	
Angle-irons, wasted dige	ester				1		1
Crowns, wasted digester			•••			2	$ar{2}$
Boiler-shell bulged over fire						1	1
Boiler-shell bulged over			1	1	2		
Crowns down					1 '	3	4
Corrosion, internal						2	2
Cylinder-joint leaking			• • •			1	1
Fire-box getting thin					1	2	3
Fire-box bulged				•••		2	2
Fire-box patched				•••	1	2	3
Fire-box leaking			•••	•••	•••	2	2
Pressure-gauges					1		1
Water-gauges						6	6
Manhole				•••	1		1
Mudhole					2	3	5
New furnace fitted					1		1
New fire-box		• • • •		•••	1		1
Fusible plugs					•••	2	2
Stays, longitudinal, brol	œn			•••		1	1
Stays screwed, wasted	•••	•••			1	2	3
Steam-pipes					1		1
Seams over fire leaking			• • • •		•••	2	2
Stripped lagging			•••			1	1
Tubes renewed				•••	1	2	3
Tubes leaky						3	3
Tube-plate leaky					•••	1	1
Test-cocks						7	7

Return of Notices given to remove dangerous parts of Machinery in the Otago District during the Financial Year ended the 31st March, 1890.

Date of Notice.	Name and Address of Owner.	Nature of Machinery, and Cause of Removal.					
26th February, 1890	New Zealand Pine Company, Invercargill, No. 1 Mill	Circular saws, two cracked — one 10in. from the centre, the other 14in. from the centre.					