The machine-running times, together with details of outages and shutdowns, are as follows:—

	Running Time.		Idle Time.		Outage Tim- (under Repair).	Outage Time on Demand.	Percentage Availability for Service.
			, , , , , , , , , , , , , , , , , , , ,	Coleridge			
	h. m.	Percentage.	h. 1	n. Percenta	ge. h. m.	h. m.	Percentage.
1	6,501 30	$74 \cdot 3$	2,141	20   24 · 4	117 10	1	98.65
2	6,203 00	70.8	1,964		590 50	2 0	$93 \cdot 26$
3	4,946 25	56.5	1,919		1,893 50		$78 \cdot 4$
4	1,916 11	21.9	5,027				$79 \cdot 3$
5	1,816 30	20.7	6,943				100.0
6	1,611 55	18.4	7,045		102 50		98.83
7	1,674 15	19.1	7,071	35   80.7	14 10		99.8
8	2,999 00	$34 \cdot 2$	5,524	$30   63 \cdot 1$	236 30	1	$97 \cdot 31$
9	3,238 35	37.0	3.841	$15 \mid 43 \cdot 7$	1,680 10		80.7
				Waitaki			
1	7,790 45	88.9	774	50   8.9	194 25	1	97.8
	7,700 07	87.9	991				99.26
$\frac{2}{3}$	6,217 08	71.0	2,365				97.98
4	5,842 07	66.7	2,739		178 10		$97 \cdot 97$
				Arnold			
1	7,978 25	91.1	1	1	781 35	1	91.08
2	8,758 05	99.9			1 55		99.98
				Dobson			'
1	107 09	1.2	+8,652			1	100.0
$\frac{1}{2}$	117 48	1.3	8,642			••	100.0
$\bar{3}$	114 55	1.3	8,645		• • •		100.0
4	17 39			$52 \begin{vmatrix} 36.7 \\ 27.1 \end{vmatrix}$	6,366 29		$\frac{100}{27 \cdot 3}$
-	2. 30			Highbank*	1 0,000 20		
Main	2,559 04	1 95.0		~	1		100.0
mam	2,000 04	35.9	4,568	$56 \mid 64 \cdot 1$	• • •	• •	100.0

<sup>\*</sup> From 8th June, 1945, only.

## (b) Transmission and Distribution

The most severe weather conditions ever recorded in the north Canterbury and Coleridge districts were experienced during the year. Sixteen inches of snow fell at Coleridge on 14th July, and lay for seven weeks in sheltered places near Coleridge village.

On 8th August heavy snow did considerable damage to the Coleridge-Hororata transmission-lines, Coleridge Station being isolated from the system for 9 hours 16 minutes.

On 31st August and 1st September a violent north-west gale swept across Canterbury, doing further damage to transmission and telephone lines.

On each of these occasions supply to consumers was seriously interrupted, the worst conditions being experienced during the July outage, when South Canterbury Power Board was without supply for 10 hours 5 minutes. Ashburton Power Board for 21 hours 13 minutes, Waitaki Power Board for 18 minutes, North Canterbury Power Board for 36 hours., and Banks Peninsula Power Board for 35 hours.

There was also a number of short interruptions to the West Coast supply due to the opening of the O.C.B.s at Coleridge during the storm. Supply to the West Coast in general was satisfactory throughout the year, there being no failures on the transmission-lines between Coleridge and that area.

Routine inspections, insulator testing, and general maintenance was performed.