DEFECTIVE FITTINGS found on Inspection of Boilers for which Notice was given to renew or repair during Financial Year ended the 31st March, 1908.

- 4 Bends of feed-pipes defective: have been renewed.
- 5 Bends of main steam-pipes bad: have been renewed.
- 19 Blow-off cocks bad: have been renewed.
- 5 Blow-off cocks defective: have been repaired.
- 2 Blow-off cocks fitted with new bolts.
- 1 Blow-off cock rejointed, and new studs fitted in boiler.
- 6 Blow-off pipes bad: have been renewed.
- 2 Brake-gear defective: has been put in order.
- 4 Crank-shafts of engine bent: have been straightened.
- 1 Crank-shafts of engine fractured: were renewed.
- 3 Cylinders, where jointed to boiler, leaking: were rejointed.
- 1 Defective clutch on shaft renewed.
- 1 Engine guide-bars broken: have been renewed.
- 2 Feed check-valve chest defective: was renewed.
- 4 Feed check-valve chests and valves bad: were renewed.
- 3 Feed check-valve chest rejointed to boiler.
- 2 Feed-pipes defective: have been renewed.
- 2 Feed-pumps defective: have been repaired.
- 40 Ferrules fitted under spring-balance safetyvalve levers.
- 3 Fly-wheels of engine defective: have been repaired.
- 1 Fly-wheel of engine cracked: was renewed.
- 1 Fly-wheel of engine loose on shaft: was made secure.
- 1 Fulcrum of safety valve defective: was renewed.
- 26 Fusible plugs found defective: have been renewed.
- 2 Governors out of order: were overhauled.
- 4 Injectors found defective: were renewed.
- 1 Main steam-pipes bad: have been renewed.
- 1 Main steam-pipes defective: were repaired.
- 3 Main steam-pipes fitted with hangers.
- 14 Manhole-doors bad: have been renewed.
- 4 Manhole door-studs bad: have been renewed.
- 38 Mudhole-doors bad: have been renewed.
- 14 Mudhole door-studs bad : have been renewed.
- 4 New crown wheels for dredge fitted.

- 1 New cylinder for engine fitted.
- 1 New feed-pump fitted.
- 1 New flange fitted to steam-pipe.
- 2 New pet-cocks fitted to feed-pump.
- New steam-cock fitted to digester.
- 1 New steering-gear bracket fitted to tractionengine to replace broken one.
- 1 New strap fitted to the end of engine connecting-rod.
- 3 New studs and nuts fitted to stop-valves.
- 2 New studs and nuts fitted to stop-valve glands.
- 11 Safety valves bad: have been renewed.
- 2 Safety-valve chests defective: have been renewed.
- 13 Safety valves defective: have been repaired.
- 29 Safety-valve levers cut to correct length.
- 1 Safety-valve spindle defective: was renewed.
- 2 Safety-valve springs bad: have been renewed.
- 3 Safety-valve weights incorrect: new ones fitted.
- 40 Steam-pressure gauges bad: have been renewed.
- 3 Steam-pressure gauge-pipes bad: were renewed.
- 2 Steam stop-valves bad: have been renewed.
- 5 Steam stop-valves refaced.
- 2 Studs in cylinder casing renewed.
- 6 Syphon pipes for steam-pressure gauges bad: were renewed.
- 7 Tapered mud-plugs defective: have been renewed.
- 8 Tapered sight-plugs defective: have been renewed.
- 14 Test-cocks bad: have been renewed.
- 8 Test-cocks defective: have been repaired.
- 1 Traction-engine brake fitted with new nut and screw.
- 8 Traction-engine steering gear defective: was put in order.
- 1 Traction-engine steering-gear wheel defective: was repaired.
- 1 Universal coupling repaired.
- 1 Water-gauge column bad: was renewed.
- 36 Water-gauge mountings bad: have been renewed.
- 30 Water-gauge mountings defective: were repaired.
- 4 Water-gauge pipes altered.