

TABLE W.—ELECTRIC-SUPPLY STATIONS OF NEW ZEALAND AT 31ST MARCH, 1928—continued.
(G = gas; O = oil; S = steam; W = water.)

Title.	Supply commenced.	Population included in Area of Supply.	Numbers of Consumers.	Capacity.		Connected Load (Kilowatts).	Demand Factor.	Units.			Annual Load-factor Percentage.	Average Units sold per Consumer.	Average Units sold per Capita.	System of Supply.	Supply Voltage.	Route-miles of Lines.	Stations in Feet.	
				Main Plant.	Stand-by Plant.			Maximum Load.	Generated or purchased.	Sold.								Non-productive.
Hydro Stations—continued.																		
Wanganui-Rangitikei Mangaweka	1924	(52,000) 345	7,293 90	K.v.a. Bulk	K.v.a. 1,650 (S) 40 (W)	K.w. (3,070) (34)	(16,032) (45.97)	19.2 73.96	(13,736,555) (86,793)	(10,989,244)* (78,831)	(2,747,311)* (7,962)	20* 9.17	1,506.8* 875.9	211.3* 228.4	A.C. A.C.	400/230 400/230	651 7	..
Wellington	1888	(100,000)	23,000	"	9,650 (S)	(12,910) 30.26	(66,363) 143	19.45 21.2	(46,313,769) 66,866	(38,742,838) 60,214	(7,570,931) 6,652	16.35 9.95	1,684.4 318.5	387 31	A.C. A.C.	400/230/105 400/230	268 5.5	..
9. Mackenzie (Fairlie)	1922	1,942	189	40	"	70	340	20.5	91,322	70,852	20,470	22.4	236.1	54.5	A.C.	440/220	8	66
10. Mataura	1913	1,300	300	75	150 (S)										A.C.	400/230		22
11. Marlborough	1927	20,780	1,340	625	..	400	2,239	17.8	664,937	292,595	372,342	56	218.3	10.5	A.C.	400/230	201	100
12. Murchison	1922	450	120	100	..	95	253	37.6	257,500	154,668	102,832	39.9	1,288.9	343.7	A.C.	400/230	14	150
13. New Plymouth	1905	21,000	5,233	3,600	500 (O)	2,400	13,010	18.4	11,043,295	9,342,665	1,700,630	15.3	1,539.9	387.8	A.C.	400/230	225	120 240
Inglewood	1905	1,300	405	Bulk	120 (W)	(110)	(1,032)	10.65	(391,155)	(279,883)	(111,272)	28.44	691	215.2	A.C.	400/230	8.12	38
Waitara	1907	1,787	429	..	..	(85)	(510)	16.6	(228,370)	(163,214)	(65,156)	28.53	380.4	91.3	A.C.	400/230	11.5	..
14. Ohakune	1914	2,400	460	120	141 (O)	101	592.35	17.06	185,265	158,419	26,846	14.49	344.3	66.0	A.C.	400/230	19	..
15. Opunake	1924	7,000	1,064	380†	..	360	1,034	34.8	1,307,400	1,041,900	265,500	20.3	979.2	148.8	A.C.	400/230	137.5	53
16. Patea	1901	1,800	310	82	80 (O)	92.4	272	33.9	273,282	232,955	40,327	14.8	751.4	129.4	A.C.	110/220	13	78
17. Queenstown	1924	804	202	100	..	55	236	23.3	131,790	94,626	37,164	28.2	467.9	117.5	A.C.	400/230	25	510
18. Raetihi	1917	4,500	392	470	..	150	650	23.07	407,530	326,124	81,406	19.97	831.9	72.4	A.C.	400/230	28	308
19. Reefton Electric Light and Power Co., Ltd.	1887	1,200	287	80	..	68	..	..	16,000	12,000	4,000	25	41.8	10	D.C.	460/230	2.25	27
20. Southland (Monowai Bluff	1925	67,090	8,033	7,050	..	4,900	32,285	15.17	21,155,905	14,968,107	6,187,798	29.24	1,667.1	1,211.2	A.C.	400/230	2,373	154
Invercargill	1903	(1,690)	380	Bulk	..	(194)	(816.37)	23.8	(330,441)	(262,100)	(68,341)	24.67	689.9	155	A.C.	400/230	9.62	..
	1913	(21,000)	3,946	"	2,450 (S)	(1,488)	(9,846)	15.1	(5,377,701)	(4,801,684)	(576,017)	10.7	1,211.7	228.6	A.C.	400/230	75	..
21. Taranaki	1925	12,285	1,511	3,600	..	1,800	5,293	34.0	4,855,260	3,884,208	971,052*	20	..	..	A.C.	400/230	252	300
Stratford	1898	3,336	908	Bulk	..	(350)	(1,673)	20.9	(1,192,814)	(990,141)	(202,673)	17	1,090.4	296.8	A.C.	400/230	19.5	..
22. Taihape	1913	2,450	564	150	75 (G)	214	906	23.6	459,010	313,020	145,990	31.8	555	127.7	D.C.	460/230	10.25	30
23. Taumarunui	1924	4,000	715	500	..	460	1,338	34.3	958,126	670,518	287,608	30	937.7	167.6	A.C.	400/230	15	25
24. Tauranga Borough Council	1915	2,500	848	4,300	..	3,566	4,642	76.82	14,211,925	11,982,350	2,229,575	15.68	1,761.6	597.5	A.C.	400/230	69.5	110/86
Tauranga Power Board	1925	8,300	788	Bulk	..	(650)	(2,881)	..	(3,459,688)	(2,883,074)	(576,614)	(16.6)	365.5	34.7	A.C.	400/230	280	..
Te Puke	1921	980	251	"	..	(84)	(515.8)	16.2	(274,015)	(258,290)	(15,725)	5.75	1,029.0	263.5	A.C.	400/230	8.75	..
25. Teviot	1924	1,580	343	750	..	645	2,076.5	31.06	2,470,446	1,976,356	494,090*	20	..	..	A.C.	400/230	65	380
Otago Central	1925	2,037	690	Bulk	..	(310)	(1,074)	28.8	(1,236,287)	(903,295)	(332,992)	26.93	1,309.1	443.4	A.C.	400/230	84	..

* Assessed.

† Also bulk supply from New Plymouth.