

TABLE W.—ELECTRIC-SUPPLY STATIONS OF NEW ZEALAND AT 31st MARCH, 1928—continued.

(G = gas; O = oil; S = steam; W = water.)

Title.	Supply commenced.	Population included in Area of Supply.	Number of Consumers.	Capacity.			Connected Load (Kilowatts).	Demand Factor.	Units.		Annual Load-factor Percentage.	Average Units sold per Consumer.	Average Units sold per Capita.	System of Supply.	Supply Voltage.	Route-miles of Lines.	Static Head, In Feet.
				Main Plant.	Stand-by Plant.	Maximum Load.			Generated or purchased.	Sold.							
Hydro Stations—contd. 26. Waikato (Horoira)	1913	271,625	19 bulk	K.v.a. 12,875	K.v.a. 3,000 (S)	K.w. 15,700	64,580	24.31	100,075,668	87,852,067	12,223,601	12.21	324	A.C.	..	656.38	27
	1922	(6,000)	1,128	Bulk	..	(506)	(2,300.6)	22.96	(3,018,937)	(2,233,997)	(784,940)	26	372.3	A.C.	400/230	141	..
	1921	(18,039)	3,015	..	..	(1,100)	(6,352)	17.32	(5,891,776)	(4,851,608)	(1,040,168)	17.65	268.9	A.C.	400/230	388.25	..
	1925	(16,359)	2,319	..	350 (G)	(727.4)	(4,311)	16.87	(3,007,981)	(2,506,651)	(501,330)	16.66	153.2	A.C.	400/230	262	..
	1913	(15,500)	3,388	..	..	(891)	(6,153)	14.43	(2,947,233)	(2,454,809)	(492,424)	16.7	158.3	A.C.	400/230	46.7	..
Te Awamutu	1920	(17,620)	1,353	..	..	(744)	(3,520.3)	21.13	(3,989,310)	(3,217,554)	(721,756)	18.12	422.2	A.C.	400/230	291.5	..
Thames Valley	1920	(140,794)	4,915	..	..	(4,359)	(16,493)	26.42	(22,669,688)	(18,024,393)	(4,645,295)	20.49	374.5	A.C.	400/230	673	..
Thames Borough Council	1914	(5,000)	1,074	..	205 (W)	(350.7)	(1,549)	22.64	(1,405,880)	(956,942)	(448,938)	31.93	191.2	A.C./D.C.	460/400/230	20	..
Te Aroha	1906	(2,324)	640	..	150 (W)	(180)	(1,135)	15.85	(610,475)	(529,389)	(181,086)	29.7	227.3	A.C.	400/230	16.25	600
Tourist Department (Rotorua)	1901	(5,500)	1,451	..	387 (G)	(390)	(2,721)	14.33	(1,403,668)	(1,034,655)	(369,013)	26.29	188.1	A.C.	400/230/200/115	45.25	14
Waitemata	1926	(36,489)	5,512	..	..	(1,172)	(10,074.8)	11.63	(5,494,849)	(4,503,238)	(991,611)	18.05	123.4	A.C.	400/230	266.9	..
Waitomo	1925	(8,000)	1,118	..	170 (G)	(276)	(1,410)	19.58	(1,328,291)	(1,000,281)	(328,010)	24.69	125	A.C.	400/230	65	300
27. Wairoa (Waikaremoana)	1923	5,341	260	2,000	..	1,042	2,963	35.16	2,792,224	2,462,077	330,147	11.82	320.6	A.C.	400/230	105.5	680
Wairoa Borough Council	1913	2,337	605	Bulk	..	(237.4)	1,756	13.55	(1,101,364)	(1,005,766)	(95,598)	8.68	430.3	A.C.	400/230	12.6	..
28. Waimea	1910	4,000	614	100 Also bulk	40 (G)	100	738	13.55	147,778	114,016	33,762	22.84	28.5	A.C.	400/230	35	11
29. Wairua (Wilson's Cement Co.)	1916	7,560	43	2,500	..	2,300	..	..	13,047,750	11,374,024	1,673,726	12.83	1,504.5	A.C.	400/230	36.38	130
Kamo	1923	(560)	90	Bulk	..	(22.8)	(110.6)	20.6	(29,971)	(23,976)	(5,995)*	20	53.5	A.C.	400/230	5.62	..
Whangarei	1915	(7,000)	1,819	..	..	(495)	(3,561)	13.9	(1,841,950)	(1,500,512)	(341,438)	18.53	214.3	A.C.	400/230	28.5	..
30. Wairere	1925	2,000	234	480	..	207	855	24.2	584,540	526,139	58,401	10	263	A.C.	400/230	72.25	65
31. Westport	1925	4,000	420	250	..	125	476	26.2	292,350	189,120	103,230	35.3	47.2	A.C.	400/230	21.5	430
32. Whakatane	1922	1,300	410	240	..	290	290	100	891,930	566,168	325,762	36.52	435.8	A.C.	400/230	25	276
Totals	..	1,175,141	196,745	114,132	27,052	8,840	508,320	17.48	427,556,602	371,162,947	56,393,655	13.19	316	..	..	15,860.46	..

* Assessed.

† Includes P.W.D. construction units.

‡ Includes units used in cement-works.